

Annexure – C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2750 / WS-93 / 99

Dated: 14/09/2026

It is certified that an inspection team headed by Mansi Maheshwari (Chemist/QM)
(Name of Officers with designation) from U.P. Jal Nigam (Rural) Moradabad PHED
inspected the Krishna Grambharti Global School, Surjan Nagar (Moradabad)
(Name & Address of the school) on 10/09/2026 (date of
inspection) and on the basis of Water Test Report (Attached) bearing no 2738 / WS-93/98 dated
11/09/2026 of

U.P. Jal Nigam (Rural) Moradabad (PHED Lab) certified that the.

Krishna Grambharti Global School, Surjan Nagar (Moradabad) (Name of school)
has safe drinking water facilities for the students and members of staff of the institution. School is also maintains
the hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/State/ U.T. Govt.

This certificate is valid till One Year from the date of issue

Signature with Seal:



Name: Mansi Maheshwari

Designation: Chemist/QM

Name & Address of the Office/Department: U.P. Jal Nigam (Rural)
Moradabad

To

Krishna Grambharti Global School
Near Police Chowki, Surjan Nagar (Moradabad) UP
244602
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

bsingh
Manager

A. Singh
Principal

Krishna Grambharti Global School
Surjannagar (Moradabad)

Krishna Grambharti Global School
Surjannagar (Moradabad)



Water Analysis Report



District Level Water Analysis Laboratory U.P. Jal Nigam (Rural) Moradabad

Office of Executive Engineer, Khand Karyalay, U.P. Jal Nigam (Rural), Ashlyana Phase-1, Near OHT, Kanth Road, Moradabad

Report No. 2738 / WS-93/98

Date: 11/09/2026

Page No. 1

ULR No. TC796626000000401F

Customer Details

Name and Address Krishna Grambharti Global School Near Police Chowki Surjan Nagar Moradabad

Ref Letter No & Date KGGs/82010/2026/48

10 Sept 2026

Basic details of sample

District	Moradabad	Block	
Gram Panchayat/ Nagar Panchayat		Village	
Habitation		Location	Krishna Grambharti Global School
Water Source	Submersible	Sample Code	C/26/09/2926
Quantity of Sample	1 L	Date of Sample Collection	10-09-2026
Receiving Date	10-09-2026	Sample Collector	Devendra Prakash
Sample Depositer	Devendra Prakash	Sampling Method Used	IS 17614 (Part 1) : 2021
Analysis Start Date	10-09-2026	Analysis Completion Date	11-09-2026

Environmental Condition during sampling: Temp./Humidity/Weather:

Temperature 25 ± 3 °C

Humidity 50 ± 15%

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable	Permissible Limit	
1	2	3	4	5	6	7
1	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
3	Colour	HU	2	5	15	IS 3025 (Part 4): 2021
4	Turbidity	(NTU)	0.99	1.00	5.00	IS 3025 (Part 10): 2023
5	pH @25°C	-	7.11	6.5-8.5	No Relaxation	IS 3025 (Part 11): 2022
6	TDS	(mg/L)	189	500	2000	IS 3025 (Part 16): 2023
7	Chloride	(mg/L)	11	250	1000	IS 3025 (Part 32): 2019
8	Fluoride	(mg/L)	0.22	1	1.5	APHA 24th Edition -4500-F Method C (Electrode Method) : 2023
9	Sulphate	(mg/L)	8.26	200	400	APHA 24th Edition -4500- SO4 Method E (Turbidimetric Method) : 2023
10	Nitrate	(mg/l)	2.16	45	No Relaxation	APHA 24th Edition -4500-NO3 Method B(UV Screening Method) : 2023
11	Iron	(mg/l)	0.36	1	No Relaxation	APHA 24th Edition -3500- Fe Method B (Phenanthroline Method): 2023
12	Total Hardness	(mg/l)	158	200	600	IS 3025 (Part 21): 2023
13	Total Alkalinity	(mg/l)	156	200	600	IS 3025 (Part 23): 2023
14	Calcium (As Ca)	(mg/l)	46.48	75.00	200.00	IS 3025 (Part 40): 2024
15	Magnesium (As Mg)	(mg/l)	10.20	30	100	IS 3025 (Part 46): 2023

All these parameters are under NABL Scope, BDL- Below Detection Limit, NA- Not Analysed

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. If the sample is supplied by customer, the results apply to the sample as received.

Prepared By



Ankar Singh

Technical Manager

UP JN, Moradabad


Principal

Krishna Grambharti Global School
Surjannagar (Moradabad)

Manager

Krishna Grambharti Global School
Surjannagar (Moradabad)

Authorized Signatory



Manish Khatiwara

Quality Manager

UP JN, Moradabad

****END OF THE ANALYSIS REPORT****



Water Analysis Report

District Level Water Analysis Laboratory U.P. Jal Nigam (Rural) Moradabad

Office of Executive Engineer, Khand Karyalay, U.P. Jal Nigam (Rural), Ashiyana Phase-1, Near OHT, Kanth Road, Moradabad

Report No. _____ Date: _____ Page No. 1

Customer Details

Name and Address: Krishna Grambharti Global School Near Police Chowki Surjan Nagar Moradabad
Ref Letter No & Date: KGGs/82010/2026/48 10 Sept 2026

Basic details of sample

District: Moradabad Block: _____
Gram Panchayat/ Nagar Panchayat: _____ Village: _____
Habitation: _____ Location: Krishna Grambharti Global School
Water Source: Submersible Sample Code: _____
Quantity of Sample: 1 L Date of Sample Collection: 10-09-2026
Receiving Date: 10-09-2026 Sample Collector: Devendra Prakash
Sample Depositer: Devendra Prakash Sampling Method Used: IS 17614 (Part 1) : 2021
Analysis Start Date: 10-09-2026 Analysis Completion Date: 11-09-2026

Environmental Condition

Temperature: 25 ± 3 °C Humidity: 50 ± 15%

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total Coliform	CFU/100 ml	0	Shall not be detectable in any 100 ml sample	No Relaxation	IS 15185: 2016
2	E Coli	CFU/100 ml	0	Shall not be detectable in any 100 ml sample	No Relaxation	

Note: 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By
(Abhishek Sagar)

Authorized Signatory
(Mansi Maheshwari)

****END OF THE ANALYSIS REPORT****

Manager

Krishna Grambharti Global School
Surjannagar (Moradabad)

Principal

Krishna Grambharti Global School
Surjannagar (Moradabad)